



Athi Water Works Development Agency  
Athi Water Plaza, Muthaiga North Road, Off Kiambu Road  
P. O Box 45283 - 00100 Nairobi  
Tel: (+254) 20 - 2724292/3. Mobile : (+254) 715 - 688272  
E-mail: info@awwda.go.ke  
www.awwda.go.ke

When replying please quote: **AWWDA/AFD/NWSP/G/03/2022-2023/cop**

21<sup>st</sup> July, 2022

**To All Bidders**

Dear Sir/Madam,

**SUPPLY AND DELIVERY OF ASSORTED PIPES AND FITTINGS**

**RE: CLARIFICATIONS TO ADVERTISED BID**

Reference is made to the ongoing procurement for Supply and Delivery of Assorted Pipes and Fittings, reference number AWWDA/AFD/NWSP/G/03/2022-2023.

Pursuant to Clause No. 7.1 of the Instructions to Bidders, please find hereby attached responses to clarifications as received by 21<sup>st</sup> July 2022.

Bidders are informed that the last date of submission of bids remains unchanged on 3<sup>rd</sup> August 2022 at 12:00pm East African Time.

**ENG. JOSEPH KAMAU  
FOR: CHIEF EXECUTIVE OFFICER**

Encl; Bid Clarifications No. 1



REPUBLIC OF KENYA  
MINISTRY OF WATER, SANITATION AND IRRIGATION



ATHI WATER WORKS DEVELOPMENT AGENCY (AWWDA)

Project Name: NAIROBI WATER AND SANITATION PROJECT

Credit No.: CKE 1135 01H



**SUPPLY AND DELIVERY OF ASSORTED PIPES AND FITTINGS**

ICB No: AWWDA/AFD/NWSP/G/03/2022-2023

**RESPONSE TO CLARIFICATIONS**

No.	Reference Section	Bidders Question	AWWDA Response
1.	Instructions to Bidders	<p><b>ITB 15.1: The currency of the bid and payment shall be: Kenya Shillings.</b></p> <p>Please clarify that bidders, can bid and be paid in a freely convertible foreign currency i.e. EURO/USD</p>	Yes, bidders can bid and be paid in a freely convertible currency
2.	Bills of Quantities	<p><b>As per the Bills of Quantities, the following sizes are non-standard</b></p> <p>DN 12.5 class 'B' GI pipe            DN 37.5 Mechanical coupling            DN 12.5 Gate valve            DN 37.5 Gate valve            DN 12.5 Lockable Gate valve            DN 37.5 Lockable Gate valve            DN 37.5 Mechanical coupling            DN 12.5 Lockable Gate valve            Kindly confirm correct standard sizes.</p>	<p>The correct standard sizes to be amended as follows:</p> <p>-</p> <p>DN 15 class 'B' GI pipe            DN 40 Mechanical coupling            DN 15 Gate valve            DN 40 Gate valve            DN 15 Lockable Gate valve            DN 40 Lockable Gate valve            DN 40 Mechanical coupling            DN 15 Lockable Gate valve</p>

SIGNED: Name Eng Bonnie Njanduro Sign  1 of 1