

When replying please quote: AWWDA/GOK/P/KICWP/W-06/2023-2024/Vol.1

31st October, 2023

To all Bidders:


**PROCUREMENT OF WORKS FOR CONSTRUCTION OF WATER PROJECTS WITHIN
AWWDA AREA OF JURISDICTION - COMPONENT 1: CONSTRUCTION OF KIAMBU
COMMUNITY WATER PROJECT. CONTRACT NO. AWWDA/GOK/P/KICWP/W-
06/2023-2024**

RESPONSE TO CLARIFICATIONS NO. 1

Reference is made to the ongoing procurement of Works for Construction of Water Projects within AWWDA Area of Jurisdiction - Component 1: Construction of Kiambu Community Water Project. IFB No.AWWDA/GOK/P/KICWP/W-06/2023-2024

Pursuant to ITT7.1 of the tender data sheet, please find attached responses to clarifications No. 1 as received by AWWDA within the specified timelines.

All bidders are further informed that the last date of submission of bids is **7th November, 2023, at 12.00pm East African Time.**



ENG. JOSEPH KAMAU,
Ag. CHIEF EXECUTIVE OFFICER.

Encl;

1. Response to Clarifications No. 1.

CLARIFICATIONS ON PROCUREMENT OF WORKS FOR CONSTRUCTION OF WATER PROJECTS WITHIN AWWDA AREA OF

JURISDICTION - Component 1: Construction of Kiambu Community Water Project

IFB No: AWWDA/GOK/P/KICWP/W-06/2023-2024

Reference Section/Volume	Bidder's Question	AWWDA Response
Bill of Quantities: Bill No.2 – Item No. 229	Item No. 229 on Bill 2- Equipping the Riu 5 Borehole, we need to understand if it is a provisional sum or a prime cost sum on the electricity supply and connection to the borehole sites. If it is a provisional sum, please confirm the amount that has been provisioned for the electricity supply connection. Let us know if it is a prime cost sum for us to input our figure on the same. We need this clarity as this item is recurring on Bill No.5 item 515 as well as Bill No.7 Item No. 732.	Allow a provisional sum of KES.750,000.00
Bill of Quantities: Bill No.5 – Item No. 515	Item No. 229 on Bill 2- Equipping the Riu 5 Borehole, we need to understand if it is a provisional sum or a prime cost sum on the electricity supply and connection to the borehole sites. If it is a provisional sum, please confirm the amount that has been provisioned for the electricity supply connection. Let us know if it is a prime cost sum for us to input our figure on the same. We need this clarity as this item is recurring on Bill No.5 item 515 as well as Bill No.7 Item No. 732.	Allow a provisional sum of KES.750,000.00
Bill of Quantities: Bill No.7 – Item No. 732	Item No. 229 on Bill 2- Equipping the Riu 5 Borehole, we need to understand if it is a provisional sum or a prime cost sum on the electricity supply and connection to the borehole sites. If it is a provisional sum, please confirm the amount that has been provisioned for the electricity supply connection. Let us know if it is a prime cost sum for us to input our figure on the same.	Allow a provisional sum of KES.750,000.00



Reference Section/Volume	Bidder's Question	AWWDA Response
	We need this clarity as this item is recurring on Bill No.5 item 515 as well as Bill No.7 Item No. 732.	
Bill of Quantities: Bill No.3	Bill No.3 on the solarization of Riu Boreholes, we need to confirm the quantities of concrete as well as the quantity of concrete to be cured as they have not been specified in the bills. The units and the quantity of the described class 25 concrete have not been included. Please provide sufficient clarity on this.	• Total Concrete quantity for the support stubs is 15m³ of class 25 • There will be 9 steel structures with 20 solar modules each

Signed By... Eng. Kurnia Raf Date... 31/10/2023