



Athi Water Works Development Agency
Athi Water Plaza, Muthaiga North Road, Off Kiambu Road
P.O Box 45283 00100 Nairobi
Tel: (+254) 20 -2724292/3. Mobile: (254) 715-688272
E-mail info@awwda go.ke
www.awwda.go.ke

When replying please quote: AWWDA/GOK/P/GLM/W-09/2024 /VOL.I (8) PE-jms

2nd February, 2024

To All Bidders;

PROCUREMENT OF WORKS FOR THE CONSTRUCTION OF WATER PROJECTS WITHIN AWWDA AREA OF JURISDICTION: CONSTRUCTION OF GATANGA LAST MILE WATER SUPPLY PROJECT: IFB NO. AWWDA/GOK/P/GLM/W-09/2024

CLARIFICATIONS TO ISSUED BIDDING DOCUMENT AND BID SUBMISSION FOR PROCUREMENT FOR WORKS

Reference is made to the ongoing procurement of Works for the Construction of Gatanga Last Mile Water Supply Project; IFB No. AWWDA/GOK/P/GLM/W-09/2024.

Pursuant to clauses ITT 7.1 of the Tender Data Sheet (TDS), please find attached responses to clarifications as received by 30th January, 2024.

Please note that the bid submission date remains 7th February, 2024 at 12:00 p.m. East Africa Time

**ENG. KIPRONO D. ROP
FOR: CHIEF EXECUTIVE OFFICER**

Encl.



GATANG'A LAST MILE WATER SUPPLY PROJECT:

TENDER NO.: AWWDA/GOK/P/GLM/W-09/2024

RESPONSE TO CLARIFICATIONS SOUGHT BY BIDDERS



S/No.	Request for Clarification / Query	Response
1.	please clarify on bill 2 I421.1 -NO PRESSURE RATING FOR THE STEEL PIPE	The pressure rating is PN16
2.	BILL NO.2 -I441.1 THERE IS NO PRESSURE RATING	The pressure rating has been specified on the description as PN16
3.	On the advertised tenders, you have requested for Audited financial statements for the last 3 years. Please clarify if 2023 financial statements are part of the requested years	Bidders are required to submit the last 3 year Audited financial statements.

SIGNED: Name.....*Jonath Shetty*..... Sign.....*[Signature]*..... 1 of 1